

CERTIFICATE



Czech

Evidence number 08.501.253

on EC type-examination (B module) according to 97/23/EC directive, as amended implemented by the Act No. 22/1997 Coll., as amended, and Government Decree No. 26/2003 Coll., as amended

awarded to the producer:

**ABO valve, s.r.o.
Dalimilova 285/54
CZ - 783 35 Olomouc
ID-No.: 49609050**

for pressure equipment:

Name: **Knife gate valve**
Type name: ABO - Series 200
Modification: DN 50 - DN 600 for a maximal allowable pressure of 10 bar
for temperatures from -50°C to +200°C
for liquids of group 1 and 2

Production place: ABO valve, s.r.o., Dalimilova 285/54, CZ - 783 35 Olomouc

This is to certify that the above-named type of the pressure equipment meets the requirements of

**The European Parliament and European Council Directive 97/23/EC,
as amended**

implemented by the Act No. 22/1997 Coll., as amended, and Government Decree No. 26/2003 Coll., as amended.


The present certificate has been issued for the purpose of Declaration of product conformity issue. The product conforms to the above-described technical directive.

Details on appraisal and a list of important parts of the technical documentation are stated within the Assessment report No. 08.513.454 from 22.10.2015, which is an integral part hereof.

Conditions related to certificate validity period and the rules of the certificate disposal are stated on the second page of the certificate.

In Prague, dated 29.10.2015




on behalf of Notified Body 1017
Jana Bačinová
Head of Quality Department